

VOC Content Test Certificate

Thursday 17th December 2020

Supplier: Parchem Construction Supplies Pty Ltd (7 Lucca Rd, Wyong, NSW 2259, Australia)

Product Description: Fosroc® Nitoflor® PA

Date Tested: December 2020 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: ASTM D3960 Standard Practice for Determining Volatile Organic Compound (VOC) Content of Paints and Related Coatings Materials. ASTM D3960 test method is referred in accordance with the laboratory testing guidance from Green Building Council of Australia.

Test Data:


Specification Green Building Council of Australia Green Star Design & As Built V1.3-13.1.1B Green Star Interiors V1.3-12.1.1B	Fosroc® Nitoflor® PA
One and Two Pack Performance Coatings for Floors: 140 grams per Liter	20 grams per Liter as VOC content per material
<p><i>We hereby certify that Fosroc® Nitoflor® PA is below the VOC Content limits of chosen categories specified by Green Star Design, Green Building Council of Australia</i></p>	



Dr. Vyt Garnys
PhD, BSc (Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant



Dr. Tuan Duong
PhD, BEng (Chem. Eng.)
Senior Consultant



Travis Hale
BSc (Biotechnology)
Senior Consultant

V2012002A